

Publication No. HT-AT-IOM-0720A Product #08499191 Rev. 0720

# Next-Gen All-Temp Low Profile Unit Coolers Air, Electric and Hot Gas Defrost Models



Shown with optional EcoNet® Enabled Controller and Command Center



# Installation and Operations Manual



### Inspection

When the equipment is received, check the quantity of cartons and crates against the bill of lading. Inspect all containers for visible damage. Report any damage or shortages to the freight company immediately. It is the customer's responsibility to file all claims with the freight company.

### Installation

Figure 1

Installation and maintenance are to be performed by qualified personnel who are familiar with local codes and regulations. Installers should have previous experience with this type of equipment.

# CAUTION: Avoid contact with sharp edges and coil surfaces. They are potential hazards.

Determine the best location for the unit in the walkin cooler or freezer. Place the unit as far as possible from any door openings. This will help to prevent warm, moist air from being drawn into the unit, reducing the potential for icing problems. Low Profile models are draw-through type units, which discharge air directly from the fan into the room.

Adequate clearances should be maintained to allow for proper air flow through the unit and to allow for regular maintenance and service (See Figure 1 for recommended location guidelines). Remove all packaging materials before the unit is raised into position. Be certain that the unit is not set on the drain fitting or refrigerant connections before installation. The unit should be hung using 5/16 inch stainless steel rods or bolts at all hanger slots. The Unit must be positioned flush with the ceiling with any gaps properly caulked.

The drain line should be pitched a minimum of 4 inches per foot to allow proper drainage and should exit the room as quickly as possible. Do not reduce the drain line size. All drain lines must be trapped outside of the enclosure where the temperature is never below 35°F. Drain lines should run to an open drain and should never be connected directly to a sewage or waste line. Drain lines should be heated and insulated to prevent freezing.

#### Wiring

All wiring must be done in compliance with local and national codes. Use only copper conductors.

Electric defrost units ar supplied with a defrost termination fan delay thermostat (DTFD). The thermostat terminates the defrost cycle when a fixed termperature is reached. Additionally, the fan delay function allows the warm coil to cool after a defrost cycle, prior tothe fans turning on. A heater safety thermostat is installed to prevent heaters from overheating above 75°F.

For wiring diagrams, see Figures 2 through 5.



### **Recommended Unit Cooler Locations**

### **Expansion Valve**

Expansion valves should be selected and installed in accordance with the valve manufacturers recommendations. All units require externally equalized expansion valves and must have the equalizer line connected. The expansion valve bulb must be insulated and securely clamped at the 4 o'clock or 8 o'clock position on a horizontal run of the suction line. Proper location and full contact of the bulb is extremely important to the performance of the system.

New expansion valves usually need to be adjusted. Superheat settings should be checked after the system has run long enough to reach a balanced state. Low and medium temperature systems will usually operate more efficiently with a superheat setting of 6.0°F at design room temperature (always maintain a 20°F compressor superheat).

To Obtain Evaporator Superheat:

- 1. Measure the suction line temperature at the expansion valve bulb with an accurate electronic thermometer.
- 2. Obtain a suction pressure reading at the Schrader fitting at the evaporator suction connection.
- 3. Convert the pressure reading to temperature by using a temperature/ pressure conversion chart.

 Subtract the converted temperature from the measured temperature. The resulting difference represents the evaporator, superheat. (For close coupled systems, it may be necessary to increase the evaporator superheat to insure the minimum acceptable superheat at the compressor.)

The maximum recommended evaporator TD for medium temperature systems is 15°F. The maximum recommended TD for low temperature systems is 13°F.

### **Evacuation**

Proper installation procedures must include a deep evacuation of the system. A clean/dry system is essential when charging refrigerant.

# **General Maintenance**

Disconnect all electrical power to the unit before inspecting or cleaning. Evaporator coils, blades and guards should be checked periodically and cleaned of all dirt or grease accumulation. Do not use ammonia or other cleaning agents that are corrosive to Copper or Aluminum. The drain pan should be lowered and thoroughly cleaned to permanently clear any drain restriction. The fan motors are permanently lubricated and do not require periodic oiling.

# **Optional Components - EcoNet® Enabled Unit Coolers**

The award-winning EcoNet Enabled Controller and EcoNet Command Center bring easy-to-use smart technology to commercial refrigeration applications.

The optional EcoNet Controller gives customers a higher level of efficiency and more control of their walk-in units for greater energy savings. The EcoNet Controller is shipped from the factory with the controller board already installed and all sensors and relays wired. The controller replaces the TXV, liquid line solenoid valve, room thermostat, time clock, and defrost termination and fan delay. Parameters are pre-selected to match equipment. The optional EcoNet Command Center allows for EcoNet Enabled Unit Coolers to be programmed, monitored, and troubleshot outside of the space being cooled. The EcoNet Command Center is shipped loose and includes everything in the box to quickly install the device on a wall outside of the walk-in. System set up is easy with the intuitive touchscreen installer settings.

If the Next-Gen All-Temp Unit Cooler has the factory-installed EcoNet Enabled Controller (see photo below), you will need to reference the EcoNet Enabled Unit Coolers Installation and Operations Manual for further assistance.



EcoNet Enabled Controller (factory-installed)

EcoNet Command Center (shipped loose)

### Next-Gen All-Temp Low Profile Unit Coolers



### Installation and Operations Manual



#### Wiring Diagram - Hot Gas Defrost



#### Figure 4

#### Wiring Diagram - Electric Defrost - 1 to 5 Fan Models



### Next-Gen All-Temp Low Profile Unit Coolers





## Installation and Operations Manual

## **Next-Gen All-Temp Replacement Parts**

Part Number	Description	
All Models or as Specified in Description		
0852833601	DRAIN PAN 1 FAN, AIR DEF	
0852833701	DRAIN PAN 2 FAN , AIR DEF	
0852833801	DRAIN PAN 3 FAN , AIR DEF	
0852833901	DRAIN PAN 4 FAN , AIR DEF	
0852834001	DRAIN PAN 5 FAN , AIR DEF	
0852834101	DRAIN PAN 6 FAN , AIR DEF	
0852833602	DRAIN PAN 1 FAN , ELECTRIC DEF	
0852833702	DRAIN PAN 2 FAN , ELECTRIC DEF	
0852833802	DRAIN PAN 3 FAN , ELECTRIC DEF	
0852833902	DRAIN PAN 4 FAN , ELECTRIC DEF	
0852834002	DRAIN PAN 5 FAN , ELECTRIC DEF	
0852834102	DRAIN PAN 6 FAN , ELECTRIC DEF	
08248171	DRAIN FITTING AL	
08321595	DRAIN NUT	
08321596	DRAIN GASKET	
08528313	VENTURI 1 FAN	
08528314	VENTURI 2 FAN	
08528315	VENTURI 3 FAN	
08528316	VENTURI 4 FAN	
08528317	VENTURI 5 FAN	
08528318	VENTURI 6 FAN	
08528319	ENDCOVER DOOR	
08216194	DUAL SPEED / DUAL VOLTAGE MOTOR, EC MOTOR, 50 WATT, 1550 RPM, 115/230V, CCW ROTATION, (Air or Electric Defrost Models)	
08218183	DUAL SPEED MOTOR RELAY 120V	
08218377	DUAL SPEED MOTOR RELAY 240V	
08216124	1 speed MOTOR, ECM, 50 WATT, 1550 RPM, 115V, CCW (Hot Gas Defrost)	
08216125	1 speed MOTOR, ECM, 50 WATT, 1550 RPM, 230V/1, CCW (Hot Gas Defrost)	
08216155	2 speed MOTOR, ECM, 50 WATT, 1550 RPM, 115V, CCW (Hot Gas Defrost)	
08216156	2 speed MOTOR, ECM, 50 WATT, 1550 RPM, 230V/1, CCW (Hot Gas Defrost)	
08216074	MOTOR, PSC, 1/20 HP, 1550 RPM, 115V	
08216073	MOTOR, PSC, 1/20 HP, 1550 RPM, 230V/1	
08216135	MOTOR, PSC, 1/20 HP, 1550 RPM, 460V/1	
08321627	MOTOR MOUNT, LEG, TALL (EC MOTORS)	

Part Number	Description	
08321628	MOTOR MOUNT, LEG, SHORT (PSC MOTORS)	
08221175	FAN BLADE, 12" DIAM., 24° PITCH, CW (For use with EC Motors)	
08221153	FAN BLADE, 12" DIAM., 24° PITCH, CW (For use with PSC Motors)	
08321626	FAN GUARD, PLASTIC, HIGH THROW, BLACK, 12"	
08219328	DEFROSTTERMINATION / FAN DELAY,SPST,O35/C55	
Electr	ic Defrost Models	
Models*L6E035, *L6E042, *L6E049, *L4E027, *L4E032, *L4E038		
08215200	COIL HEATER, 1F, 230V, 375 WATTS	
08215206	DRAIN PAN HEATER, 1F, 230V, 375 WATTS	
08215212	DRAIN PAN HEATER, 1F, 460V, 375 WATTS	
Models *L6E066, *L6E077, *L6E090, *L6E105, *L4E051, *L4E064, *L4E080		
08215201	COIL HEATER, 2F, 230V, 750 WATTS	
08215207	DRAIN PAN HEATER, 2F, 230V, 750 WATTS	
08215213	DRAIN PAN HEATER, 2F, 460V, 750 WATTS	
Models *L6E121,	*L4E094, *L6E142, *L4E110	
08215202	COIL HEATER, 3F, 230V, 1100 WATTS	
08215208	DRAIN PAN HEATER, 3F, 230V, 1100 WATTS	
08215214	DRAIN PAN HEATER, 3F, 460V, 1100 WATTS	
Models *L6E162,	*L4E125, *L6E182, *L4E141	
08215203	COIL HEATER, 4F, 230V 1475 WATTS	
08215209	DRAIN PAN HEATER, 4F, 230V, 1475 WATTS	
08215215	DRAIN PAN HEATER, 4F, 460V, 1475 WATTS	
Models	*L6E200, *L4E155	
08215204	COIL HEATER, 5F, 230V 1850 WATTS	
08215210	DRAIN PAN HEATER, 5F, 230V, 1850 WATTS	
08215216	DRAIN PAN HEATER, 5F, 460V, 1850 WATTS	
Models *L6E244, *L4E195, *L6E281, *L4E230		
08215205	COIL HEATER, 6F, 230V 2225 WATTS	
08215211	DRAIN PAN HEATER, 6F, 230V, 2225 WATTS	
08215217	DRAIN PAN HEATER, 6F, 460V, 2225 WATTS	

#### Notes:

\* Variable for brand character (R = Russell, K = Kramer, W = Witt, C = ColdZone).

Continued on next page

The Heater voltage will line up with the voltage code in the model number. Each unit will get 3 heaters (2 on the face of the coil and 1 in the drain pan). 460V units include (2) 230V face heaters wired in series. The drain pan contains a single 460V heater.

### Next-Gen All-Temp Low Profile Unit Coolers

Next-Gen All-Temp	<b>Replacement Parts</b>	Cont.
-------------------	--------------------------	-------

Part Number	Description	
Hot Gas Defrost Models		
Models *L6G035, *L6G042, *LG049, *L4G027, *L4G032, *L4G038, *L6H035, *L6H042, *LH049, *L4H027, *L4H022, *L4H022, *L4H023		
08530726	DRAIN PAN HEATER, 1F, 115V, 375	
08215206	DRAIN PAN HEATER, 1F, 230V, 375 WATTS	
08215212	DRAIN PAN HEATER, 1F, 460V, 375 WATTS	
Models *L6G066, *L6G077, *L6G090, *L6G105, *L4G051, *L4G064, *L4G080, *L6H066, *L6H077, *L6H090, *L6H105, *L4H051, *L4H064, *L4H080		
08530727	DRAIN PAN HEATER, 2F, 115V, 750 WATTS	
08215207	DRAIN PAN HEATER, 2F, 230V, 750 WATTS	
08215213	DRAIN PAN HEATER, 2F, 460V, 750 WATTS	
Models *L6G121, *L4G094, *L6G142, *L4G110, *L6H121, *L4H094, *L6H142, *L4H110		
08530728	DRAIN PAN HEATER, 3F, 115V, 1100 WATTS	
08215208	DRAIN PAN HEATER, 3F, 230V, 1100 WATTS	
08215214	DRAIN PAN HEATER, 3F, 460V, 1100 WATTS	

Part Number	Description	
Models *L6G162, *L4G125, *L6G182, *L4G141, *L6H162, *L4H125, *L6H182, *L4H141		
08530729	DRAIN PAN HEATER, 4F,115V, 1475 WATTS	
08215209	DRAIN PAN HEATER, 4F, 230V, 1475 WATTS	
08215215	DRAIN PAN HEATER, 4F, 460V, 1475 WATTS	
Models *L6G200, *L4G155, *L6H200, *L4H155		
08530730	DRAIN PAN HEATER, 5F, 115V, 1850 WATTS	
08215210	DRAIN PAN HEATER, 5F, 230V, 1850 WATTS	
08215216	DRAIN PAN HEATER, 5F, 460V, 1850 WATTS	
Models *L6G244, *L4G195, *L6G281, *L4G230, *L6H244, *L4H195, *L6H281, *L4H230		
08530731	DRAIN PAN HEATER, 6F, 115V, 2225 WATTS	
08215211	DRAIN PAN HEATER, 6F, 230V, 2225 WATTS	
08215217	DRAIN PAN HEATER, 6F, 460V, 2225 WATTS	

#### Notes:

\* Variable for brand character (R = Russell, K = Kramer, W = Witt, C = ColdZone).

The Heater voltage will line up with the voltage code in the model number. Each unit will get 3 heaters (2 on the face of the coil and 1 in the drain pan). 460V units include (2) 230V face heaters wired in series. The drain pan contains a single 460V heater.

### TO INQUIRE OR ORDER REPLACEMENT PARTS

Email: parts@htpg.com Telephone: 1-855-HTPARTS (1-855-487-2787) Fax: (256) 259-7478

- 1. Provide the complete Model Number and Serial Number of the unit.
- 2. Provide a detailed description of the part with any model, diameter, HP, or other markings.
- 3. State the quantity you are ordering.
- 4. Advise special shipping methods, routes, procedures, or instructions with ship to address.
- 5. Provide complete and accurate data to insure prompt and accurate delivery.

Due to continuing product development, specifications are subject to change without notice.

A member of the Rheem family of brands